

~~CONFIDENTIAL~~

MEMORANDUM FOR THE RECORD

4 December 1953

25X1A SUBJECT: 250 KW Generator []

25X1A

25X1A


1. [] called yesterday to report the fact that the 250 KW Generator [] has been out of service for approximately two weeks due to a faulty base. Working with Communications there has been installed a temporary replacement of 60 KW capacity which is only enough to meet present needs.

2. In order to meet anticipated emergency needs, [] has tried to get Communications to install another 60 KW in parallel to augment the capacity. Also he has been needling Logistics to take the necessary action to get the 250 KW back into operation. He indicated there is nothing this Office could do to assist at this time but simply wanted to report the facts.

25X1A

JOHN S. WARNER

25X1



25X1

JBW:djm
O-DD/A Subj: []
1-DD/A Chrono.

~~CONFIDENTIAL~~